

1512 S BATAVIA AVENUE  
GENEVA, IL 60134

An  ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

630-232-0104

## Test Report

FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

SPONSOR: **Focal Point Lights**  
Chicago, IL

**Sound Absorption**  
**RAL™-A19-531**

CONDUCTED: 2019-12-16

Page 1 of 8

ON: Nivo Acoustic, 2 ft x 2 ft, 1 in. Drop

### TEST METHODOLOGY

Riverbank Acoustical Laboratories™ is accredited by the U.S. Department of Commerce, National Institute of Standards and Technology (NIST) under the National Voluntary Laboratory Accreditation Program (NVLAP) as an ISO 17025:2017 Laboratory (NVLAP Lab Code: 100227-0) and for this test procedure. The test reported in this document conformed explicitly with ASTM C423-17: "Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method." The specimen mounting was performed according to ASTM E795-16: "Standard Practices for Mounting Test Specimens During Sound Absorption Tests." A description of the measurement procedure and room specifications are available upon request. The results presented in this report apply to the sample as received from the test sponsor.

### INFORMATION PROVIDED BY SPONSOR

The test specimen was designated by the sponsor as Nivo Acoustic, 2 ft x 2 ft, 1 in. Drop. The following nominal product information was provided by the sponsor prior to testing. The accuracy of such sponsor-provided information can affect the validity of the test results.

#### **Product Under Test**

---

Trade Name: Nivo Acoustic, 2 ft x 2 ft, 1 in. Drop  
Materials: Formed polyethylene terephthalate panels  
Nominal thickness @ 9 mm (0.354 in.)  
Manufacturer: Focal Point Lights

### SPECIMEN MEASUREMENTS & TEST CONDITIONS

Through a full external visual inspection performed on the test specimen, Riverbank personnel verified the following information:

#### **Test Specimen**

---

Material: Semirigid felt base panels with flat felt protrusions  
Dimensions: 16 @ 603.25 mm (23.75 in.) x 603.25 mm (23.75 in.)  
Thickness: Base panels @ 9.02 - 9.48 mm (0.355 - 0.373 in.)  
Overall @ 35.81 mm (1.41 in.)  
Overall Weight: 23.13 kg (51 lbs)

**Test Report****Focal Point Lights**  
2019-12-16**RAL™-A19-531**  
Page 2 of 8**Overall Specimen Properties**

Size: 2.41 m (95.0 in) wide by 2.41 m (95.0 in) long  
Thickness: 0.04 m (1.409 in)  
Weight: 23.13 kg (51.0 lbs)  
Mass per Unit Area: 3.97 kg/m<sup>2</sup> (0.81 lbs/ft<sup>2</sup>)  
Calculation Area: 5.822 m<sup>2</sup> (62.67 ft<sup>2</sup>)

**Test Environment**

Room Volume: 291.98 m<sup>3</sup>  
Temperature: 21.4 °C ± 0.3 °C (Requirement: ≥ 10 °C and ≤ 5 °C change)  
Relative Humidity: 65.1 % ± 1.0 % (Requirement: ≥ 40 % and ≤ 5 % change)  
Barometric Pressure: 99.4 kPa (Requirement not defined)

**MOUNTING METHOD**

Type E-400 Mounting: The test specimen was mounted on the top face of a metal fixture with enclosed perimeter edges, with an airspace behind the specimen. The specimen was supported by an array of adjustable metal slats spanning the fixture, spaced approximately 609.6 mm (24 in.) on center. The numeral suffix in the designation is the defined by the standard as the distance in millimeters from the exposed face of the test specimen to the horizontal test surface, rounded to the nearest integer multiple of 5. For the purposes of this test report, the mounting designation uses the face of the base panels as the reference. Perimeter edges of the specimen were sealed with metal framing.



1512 S BATAVIA AVENUE  
GENEVA, IL 60134  
630-232-0104

An **ALION** Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

**Test Report**

**RAL™-A19-531**

Page 3 of 8

**Focal Point Lights**

2019-12-16



Figure 1 – Specimen mounted in test chamber



Figure 2 – Detail of specimen materials

1512 S BATAVIA AVENUE  
 GENEVA, IL 60134  
 630-232-0104

An **ALION** Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY  
 WALLACE CLEMENT SABINE

**Test Report**

**RAL™-A19-531**

Page 4 of 8

**Focal Point Lights**

2019-12-16

TEST RESULTS

Specimen total absorption and absorption coefficient are tabulated at the eighteen standard frequencies. A graphic presentation of the data and additional information appear on the following pages.

1/3 Octave Center

Frequency (Hz)	Total Absorption (m <sup>2</sup> )	Total Absorption (Sabins)	Absorption Coefficient
100	5.66	60.93	0.97
** 125	5.35	57.54	0.92
160	5.05	54.40	0.87
200	5.36	57.72	0.92
** 250	5.46	58.74	0.94
315	5.18	55.73	0.89
400	4.93	53.09	0.85
** 500	5.11	55.03	0.88
630	5.45	58.72	0.94
800	5.76	61.97	0.99
** 1000	6.27	67.48	1.08
1250	6.60	71.01	1.13
1600	6.71	72.26	1.15
** 2000	7.04	75.74	1.21
2500	6.95	74.77	1.19
3150	6.98	75.09	1.20
** 4000	7.22	77.68	1.24
5000	7.31	78.69	1.26

**SAA = 1.01**

**NRC = 1.05**



RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

1512 S BATAVIA AVENUE  
GENEVA, IL 60134  
630-232-0104

An **ALION** Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

**Test Report**


**Focal Point Lights**  
2019-12-16

**RAL™-A19-531**  
Page 5 of 8


TEST RESULTS (continued)

The sound absorption average (SAA) is defined in ASTM C423-17 Section 3.1.1 as the arithmetic average of the sound absorption coefficients of a material for the twelve one-third octave bands from 200 Hz through 2500 Hz, inclusive, rounded to the nearest integer multiple of 0.01.

The noise reduction coefficient (NRC) is defined from previous versions of ASTM C423 as the arithmetic average of the sound absorption coefficients at 250 Hz, 500 Hz, 1000 Hz, and 2000 Hz, rounded to the nearest integer multiple of 0.05.

Tested by   
Marc Sciaky  
Senior Experimentalist

Report by   
Malcolm Kelly  
Acoustical Test Engineer

Approved by   
Eric P. Wolfram  
Laboratory Manager

 Digitally signed by Eric P. Wolfram  
Location: Geneva, IL  
Date: 2020.01.07 14:58:00 -06'00'



1512 S BATAVIA AVENUE  
GENEVA, IL 60134  
630-232-0104

An ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

Test Report


RAL™-A19-531

Page 6 of 8

Focal Point Lights  
2019-12-16

SOUND ABSORPTION REPORT

Nivo Acoustic, 2 ft x 2 ft, 1 in. Drop



SAA = 1.01

NRC = 1.05



RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

1512 S BATAVIA AVENUE  
 GENEVA, IL 60134  
 630-232-0104

An **ALION** Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY  
 WALLACE CLEMENT SABINE

**Test Report**

**Focal Point Lights**  
 2019-12-16

**RAL™-A19-531**  
 Page 7 of 8

**APPENDIX A: Extended Frequency Range Data**

Specimen: Nivo Acoustic, 2 ft x 2 ft, 1 in. Drop (See Full Report)

*The following non-accredited data were obtained in accordance with ASTM C423-17, but extend beyond the defined frequency range of 100Hz to 5,000Hz. These unofficial results are representative of the RAL test environment only and intended for research & comparison purposes.*

1/3 Octave Band Center Frequency (Hz)	Total Absorption (Sabins)	Absorption Coefficient
31.5	30.02	0.48
40	16.36	0.26
50	86.47	1.38
63	38.57	0.62
80	43.25	0.69
100	60.93	0.97
125	57.54	0.92
160	54.40	0.87
200	57.72	0.92
250	58.74	0.94
315	55.73	0.89
400	53.09	0.85
500	55.03	0.88
630	58.72	0.94
800	61.97	0.99
1000	67.48	1.08
1250	71.01	1.13
1600	72.26	1.15
2000	75.74	1.21
2500	74.77	1.19
3150	75.09	1.20
4000	77.68	1.24
5000	78.69	1.26
6300	80.50	1.28
8000	87.64	1.40
10000	94.47	1.51
12500	101.60	1.62



RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

1512 S BATAVIA AVENUE  
GENEVA, IL 60134  
630-232-0104

An ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

## Test Report

**RAL™-A19-531**

Page 8 of 8

**Focal Point Lights**

2019-12-16

### **APPENDIX B: Instruments of Traceability**

Specimen: Nivo Acoustic, 2 ft x 2 ft, 1 in. Drop (See Full Report)

<b><u>Description</u></b>	<b><u>Model</u></b>	<b><u>Serial Number</u></b>	<b><u>Date of Certification</u></b>	<b><u>Calibration Due</u></b>
System 1	Type 3160-A-042	3160-106968	2019-06-25	2020-06-25
Bruel & Kjaer Mic And Preamp A	Type 4943-B-001	2311428	2019-09-27	2020-09-27
Bruel & Kjaer Pistonphone	Type 4228	2781248	2019-08-09	2020-08-09
Omega Digital Temp., Humid. And Pressure Recorder	OM-CP-PRHTemp2000	P97844	2019-02-08	2020-02-08

### **APPENDIX C: Revisions to Original Test Report**

Specimen: Nivo Acoustic, 2 ft x 2 ft, 1 in. Drop (See Full Report)

<b><u>Date</u></b>	<b><u>Revision</u></b>
2020-01-02	Original report issued

---

END