

1512 S BATAVIA AVENUE  
GENEVA, IL 60134

An  ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

630-232-0104

## Test Report

FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

SPONSOR: **Focal Point Lights**  
Chicago, IL

**Sound Absorption**  
**RAL™-A19-533**

CONDUCTED: 2019-12-16

Page 1 of 8

ON: Acoustic Tile, 2 ft x 2 ft, 4 in. Angled (aligned orientation)

### TEST METHODOLOGY

Riverbank Acoustical Laboratories™ is accredited by the U.S. Department of Commerce, National Institute of Standards and Technology (NIST) under the National Voluntary Laboratory Accreditation Program (NVLAP) as an ISO 17025:2017 Laboratory (NVLAP Lab Code: 100227-0) and for this test procedure. The test reported in this document conformed explicitly with ASTM C423-17: "Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method." The specimen mounting was performed according to ASTM E795-16: "Standard Practices for Mounting Test Specimens During Sound Absorption Tests." A description of the measurement procedure and room specifications are available upon request. The results presented in this report apply to the sample as received from the test sponsor.

### INFORMATION PROVIDED BY SPONSOR

The test specimen was designated by the sponsor as Acoustic Tile, 2 ft x 2 ft, 4 in. Angled (aligned orientation). The following nominal product information was provided by the sponsor prior to testing. The accuracy of such sponsor-provided information can affect the validity of the test results.

#### **Product Under Test**

---

Trade Name: Acoustic Tile, 2 ft x 2 ft, 4 in. Angled  
Materials: Formed polyethylene terephthalate felt panels  
Nominal thickness @ 9 mm (0.354 in.)  
Manufacturer: Focal Point Lights

### SPECIMEN MEASUREMENTS & TEST CONDITIONS

Through a full external visual inspection performed on the test specimen, Riverbank personnel verified the following information:

#### **Test Specimen**

---

Material: Semirigid felt base panels with variable-depth protrusions  
Dimensions: 16 @ 603.25 mm (23.75 in.) x 603.25 mm (23.75 in.)  
Thickness: Base panels @ 9.33 - 9.95 mm (0.367 - 0.392 in.)  
Maximum protrusion @ 106 mm (4.173 in.) from base  
Minimum protrusion @ 26 mm (1.024 in.) from base  
Maximum overall @ 113.46 mm (4.467 in.)  
Overall Weight: 25.17 kg (55.5 lbs)  
Installation: Tiles all oriented in same direction

1512 S BATAVIA AVENUE  
GENEVA, IL 60134  
630-232-0104

An ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

## Test Report

**Focal Point Lights**  
2019-12-16

**RAL™-A19-533**  
Page 2 of 8

### Overall Specimen Properties

Size: 2.41 m (95.0 in) wide by 2.41 m (95.0 in) long  
Thickness: 0.11 m (4.467 in)  
Weight: 25.17 kg (55.5 lbs)  
Mass per Unit Area: 4.32 kg/m<sup>2</sup> (0.89 lbs/ft<sup>2</sup>)  
Calculation Area: 5.823 m<sup>2</sup> (62.67 ft<sup>2</sup>)

### Test Environment

Room Volume: 291.98 m<sup>3</sup>  
Temperature: 21.3 °C ± 0.1 °C (Requirement: ≥ 10 °C and ≤ 5 °C change)  
Relative Humidity: 64.3 % ± 2.0 % (Requirement: ≥ 40 % and ≤ 5 % change)  
Barometric Pressure: 99.3 kPa (Requirement not defined)

### MOUNTING METHOD

Type E-400 Mounting: The test specimen was mounted on the top face of a metal fixture with enclosed perimeter edges, with an airspace behind the specimen. The specimen was supported by an array of adjustable metal slats spanning the fixture, spaced approximately 609.6 mm (24 in.) on center. The numeral suffix in the designation is the defined by the standard as the distance in millimeters from the exposed face of the test specimen to the horizontal test surface, rounded to the nearest integer multiple of 5. For the purposes of this test report, the mounting designation uses the face of the base panels as the reference. Perimeter edges of the specimen were sealed with metal framing.



1512 S BATAVIA AVENUE  
GENEVA, IL 60134  
630-232-0104

An **ALION** Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

**Test Report**

**RAL™-A19-533**

Page 3 of 8

**Focal Point Lights**

2019-12-16



Figure 1 – Specimen mounted in test chamber



Figure 2 – Detail of individual tile, varying protrusion depth

1512 S BATAVIA AVENUE  
 GENEVA, IL 60134  
 630-232-0104

An **ALION** Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY  
 WALLACE CLEMENT SABINE

**Test Report**

**RAL™-A19-533**

Page 4 of 8

**Focal Point Lights**

2019-12-16

TEST RESULTS

Specimen total absorption and absorption coefficient are tabulated at the eighteen standard frequencies. A graphic presentation of the data and additional information appear on the following pages.

1/3 Octave Center

Frequency (Hz)	Total Absorption (m <sup>2</sup> )	Total Absorption (Sabins)	Absorption Coefficient
100	6.14	66.09	1.05
** 125	6.56	70.58	1.13
160	5.57	59.99	0.96
200	6.06	65.18	1.04
** 250	6.00	64.58	1.03
315	5.82	62.69	1.00
400	5.64	60.74	0.97
** 500	6.18	66.53	1.06
630	6.43	69.21	1.10
800	6.81	73.34	1.17
** 1000	6.88	74.11	1.18
1250	7.25	77.99	1.24
1600	7.21	77.56	1.24
** 2000	7.13	76.75	1.22
2500	7.16	77.03	1.23
3150	7.15	76.93	1.23
** 4000	7.45	80.23	1.28
5000	7.63	82.13	1.31

**SAA = 1.12**

**NRC = 1.10**



RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

1512 S BATAVIA AVENUE  
GENEVA, IL 60134  
630-232-0104

An ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

Test Report

Focal Point Lights  
2019-12-16

RAL™-A19-533  
Page 5 of 8

TEST RESULTS (continued)

The sound absorption average (SAA) is defined in ASTM C423-17 Section 3.1.1 as the arithmetic average of the sound absorption coefficients of a material for the twelve one-third octave bands from 200 Hz through 2500 Hz, inclusive, rounded to the nearest integer multiple of 0.01.

The noise reduction coefficient (NRC) is defined from previous versions of ASTM C423 as the arithmetic average of the sound absorption coefficients at 250 Hz, 500 Hz, 1000 Hz, and 2000 Hz, rounded to the nearest integer multiple of 0.05.

Tested by Marc Sciaky  
Marc Sciaky  
Senior Experimentalist

Report by Malcolm Kelly  
Malcolm Kelly  
Acoustical Test Engineer

Approved by Eric P. Wolfram  
Eric P. Wolfram  
Laboratory Manager

Digitally signed by Eric P Wolfram  
Location: Geneva, IL  
Date: 2020.01.07 14:58:37 -06'00'



1512 S BATAVIA AVENUE  
GENEVA, IL 60134  
630-232-0104

An ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

Test Report


Focal Point Lights  
2019-12-16

RAL™-A19-533

Page 6 of 8

SOUND ABSORPTION REPORT

Acoustic Tile, 2 ft x 2 ft, 4 in. Angled (aligned orientation)



Frequency (Hz)

SAA = 1.12

NRC = 1.10



RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

1512 S BATAVIA AVENUE  
 GENEVA, IL 60134  
 630-232-0104

An **ALION** Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY  
 WALLACE CLEMENT SABINE

**Test Report**

**RAL™-A19-533**

Page 7 of 8

**Focal Point Lights**

2019-12-16

**APPENDIX A: Extended Frequency Range Data**

Specimen: Acoustic Tile, 2 ft x 2 ft, 4 in. Angled (aligned orientation) (See Full Report)

*The following non-accredited data were obtained in accordance with ASTM C423-17, but extend beyond the defined frequency range of 100Hz to 5,000Hz. These unofficial results are representative of the RAL test environment only and intended for research & comparison purposes.*

1/3 Octave Band Center Frequency (Hz)	Total Absorption (Sabins)	Absorption Coefficient
31.5	25.59	0.41
40	20.90	0.33
50	97.42	1.55
63	33.28	0.53
80	59.42	0.95
100	66.09	1.05
125	70.58	1.13
160	59.99	0.96
200	65.18	1.04
250	64.58	1.03
315	62.69	1.00
400	60.74	0.97
500	66.53	1.06
630	69.21	1.10
800	73.34	1.17
1000	74.11	1.18
1250	77.99	1.24
1600	77.56	1.24
2000	76.75	1.22
2500	77.03	1.23
3150	76.93	1.23
4000	80.23	1.28
5000	82.13	1.31
6300	84.05	1.34
8000	89.75	1.43
10000	91.33	1.46
12500	95.25	1.52



RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

1512 S BATAVIA AVENUE  
GENEVA, IL 60134  
630-232-0104

An ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

## Test Report

**RAL™-A19-533**

Page 8 of 8

**Focal Point Lights**

2019-12-16

### **APPENDIX B: Instruments of Traceability**

Specimen: Acoustic Tile, 2 ft x 2 ft, 4 in. Angled (aligned orientation) (See Full Report)

<b><u>Description</u></b>	<b><u>Model</u></b>	<b><u>Serial Number</u></b>	<b><u>Date of Certification</u></b>	<b><u>Calibration Due</u></b>
System 1	Type 3160-A-042	3160-106968	2019-06-25	2020-06-25
Bruel & Kjaer Mic And Preamp A	Type 4943-B-001	2311428	2019-09-27	2020-09-27
Bruel & Kjaer Pistonphone	Type 4228	2781248	2019-08-09	2020-08-09
Omega Digital Temp., Humid. And Pressure Recorder	OM-CP-PRHTemp2000	P97844	2019-02-08	2020-02-08

### **APPENDIX C: Revisions to Original Test Report**

Specimen: Acoustic Tile, 2 ft x 2 ft, 4 in. Angled (aligned orientation) (See Full Report)

<b><u>Date</u></b>	<b><u>Revision</u></b>
2020-01-03	Original report issued

---

END